



# Certificate of Conformity

**Certificate No.:** 2088AP0511N080049  
**Equipment:** Solar Grid-tied Inverter

**Brand Name:** 

**Test Model No.:** SOFAR 15KTLX-G3, SOFAR 17KTLX-G3, SOFAR 20KTLX-G3,  
SOFAR 22KTLX-G3, SOFAR 24KTLX-G3

**Applicant:** Shenzhen SOFARSOLAR Co., Ltd.  
401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community,  
XinAn Street, BaoAn District, Shenzhen, China

**Report No.:** PVSP200511N080-6

## Use in accordance with regulations:

The previously listed inverters are single-phase and have an automatic disconnection / connection device controlled by software, in accordance with the regulations stated below. The end user will not have access to the adjustment software.

## Applied rules and standards

### UNE 206006 IN:2011

Island operation detection tests of multiple photovoltaic inverters connected to a parallel network

### UNE 206007-1 IN:2013

Requirements for connection to the electricity network Part 1: Inverters for connection to the distribution network

### DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage network



**Name: James Huang**  
**Technical Manager/ New Energy Team**  
**Date: 2021-03-12**

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.  
Information given in this document is related to the tested specimen of the described electrical sample.